



KING MONGKUT'S UNIVERSITY OF TECHNOLOGY THONBURI
INSTITUTE FOR SCIENTIFIC AND TECHNOLOGICAL RESEARCH AND SERVICES

126 PRACHA-U-THIT RD., BANGMOD, THUNGKRU, BANGKOK 10140 THAILAND
Tel. +66 2470-9671-3, +66 2470-9664-7 Fax +66 2428-3374 <http://www.kmutt.ac.th>

Our ref : ISTRS/57504-2

September 10, 2014

Subject : Report of test the physical properties of the specimens, "INNOWALL ," one piece of sample.

Dear sir : GREEN BIULD INNOWALL CO.,LTD

The Institute for Scientific and Technological Research and Services, King Mongkut's University of Technology Thonburi has testing the physical properties of the specimens, "INNOWALL," one piece of sample.". Result are as the following"-

Items	Specimens	RESULTS		
		VERTICAL POSITION, ASTM D 568	HORIZONTAL POSITION, ASTM D 635	WATER ABSORPTION , ASTM D 570 , % by wt.
1.	INNOWALL NO.1	NONFLAMMABLE	NONFLAMMABLE	8.97
2.	INNOWALL NO.2	NONFLAMMABLE	NONFLAMMABLE	8.98
3.	INNOWALL NO.3	NONFLAMMABLE	NONFLAMMABLE	9.39

Very truly yours,

N. Buranajant

(Ass.Prof.Nithi Buranajant)

Director Institute for Scientific and
Technological Research and Services

OUNSA

(Mr.Ounsa Nonphala)

Analyst/Scientist

OUNSA

(Mr.Ounsa Nonphala)

Laboratory Manager